

18 January 1954

25X1A9a



Subject: Gypsum Board & Acoustical Tile  
Ceilings of Corridors and  
Reference Spaces

25X1A9a

Dear Mr. [REDACTED]:

Referring to your letter of 12 January 1954, same subject, the decision to handle the matter as specified was reached at the request of the mechanical engineers. The heating and air-conditioning system of the building, being designed to meet greatly varying demands of the different spaces, is quite complex and will require many adjustments for a period of several months after inception of normal operations in order to regulate pneumatic control motors, etc., under actual working conditions. It was therefore felt advisable to omit the work in question from the original construction contract.

Very truly yours,

25X1A9a

